



RELEVANT ADA SECTIONS:

303.3 BEVELED: Changes between 1/4" minimum and 1/2" maximum shall be beveled with a slope not greater than 1:2

303.4 RAMPS: Changes greater than 1/2" shall be ramped and comply with 405 or 406

405.2 SLOPE: Ramp runs shall have a running slope not steeper than 1:12