

HARDWIRE SINGLE CIRCUIT INSTALLATION SHEET

For INTERCEPT HW, INTERFACE HW & INTERACT HW

Warning: It is recommended that a qualified electrician install any and all electrical equipment. Installation of all ECA products shall be in accordance with The National Electrical Code and all other applicable codes.

Disconnect all power to the circuit prior to installing any ECA product, or performing any preliminary work on that circuit in order to install any ECA product.

1. Ensure power is disconnected.
2. Securely attach cable from unit to junction box using appropriate connector. Ensure that the routing of the cable will not effect the proper operation of the unit.
3. Connect wire from unit to source as described below:

Green wire	to	Circuit Ground
White wire	to	Circuit Neutral
Black wire	to	Circuit Hot

4. Properly dress wires and close junction box.
5. Reconnect power and test unit for continuity and grounding.